WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 73468
Permit No.
Basin 105

NOTICE OF INTENT NO. 38857

1. OWNER Butch Quillen
MAILING ADDRESS 1475 Wild Iris
Gardnerville NV 89428

ADDRESS AT WELL LOCATION 1475 Wild Iris
Gardnerville NV

2. LOCATION NW ¼ SE ¼ Sec. 36 T. 13 N/S R. 20 E. Douglas County
PERMIT NO. Issued by Water Resources | 23-473-130 Parcel No. | Wildflower Area Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
overburden		0	4	4
Hard Pan Clay		4	12	8
Course Gravels and Cemented Gravels		12	86	74
Dry Brown Clay Small Cemented Gravels		86	147	61
Brown Clay		147	176	29
Gummy Brown Clay		176	235	59
Fractured Gravels	XXX	235	265	30
Gray Clay		265	270	5

Date started 8-30, 19 98
Date completed 9-1, 19 98

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20-25	80	2 HRS

8. WELL CONSTRUCTION
Depth Drilled 270 Feet Depth Cased 270 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 3/4 Inches	0 Feet	270 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10 5/8	13.03	.188	0	270

Perforations:
Type perforation Mill Slot
Size perforation 3x3/32
From 250 feet to 270 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 55
Placement Method: ☑ Pumped ☑ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☑ Yes ☐ No
From 55 feet to 270 feet

9. WATER LEVEL
Static water level 110' feet below land surface
Artesian flow G.P.M. 20-25 P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Capital City Well Drilling (Contractor)
Address 20 Kit Kat DR (Contractor)
Carson City NV 89706
Nevada contractor's license number issued by the State Contractor's Board 41775
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed Michael L Hall (By driller performing actual drilling on site or contractor)
Date 9-1-98

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627