WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 73469
Permit No.
Basin 105

NOTICE OF INTENT NO. 38870

1. OWNER G A Kirka Const.
MAILING ADDRESS 2567 Business Parkway Minden NV
ADDRESS AT WELL LOCATION 257 Laura Springs Minden NV 89423

2. LOCATION SW ¼ SW ¼ Sec. 34 T. 13 N/S R. 19 E. Gardnerville County
PERMIT NO. Issued by Water Resources
17-310-05 Parcel No.
Foothills Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Course DG Sands Brown Dirt.		0	18	18
Gray Clay Small Black Sands		18	63	45
Brown Clay		63	94	31
Brown Rusty Clay Seams		94	120	26
Course DG Sands	XXX	120	160	40

RECEIVED 98 JAN 19 AM 8:33 NEVADA ENGINEER-WR-DIVE

Date started 1-10, 1998
Date completed 1-13, 1998

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
257	60	4 HRS

8. WELL CONSTRUCTION
Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 3/4 Inches	0 Feet	160 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
16 5/8	13.03	.188	0	160

Perforations:
Type perforation Mill Slot
Size perforation 3X 3132
From 140 feet to 160 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 100'
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 100 feet to 160 feet

9. WATER LEVEL
Static water level 0 feet below land surface
Artesian flow 15 G.P.M. 257 P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Capital City Well Drilling Contractor
Address 20 Kit Kat Dr. Contractor
Carson City NV 89706
Nevada contractor's license number issued by the State Contractor's Board 41775
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed [signature] By driller performing actual drilling on site or contractor
Date 1-13-98

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627