WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 73470
Permit No.
Basin HDR 105

NOTICE OF INTENT NO. 28168

1. OWNER Don Keith
MAILING ADDRESS
ADDRESS AT WELL LOCATION 1900 Pinenut Rd #1 Gardnerville NV. 89410

2. LOCATION SE ¼ NW ¼ Sec. 12 T. 12 N/S R. 20 E Douglas County
PERMIT NO. (Issued by Water Resources) Parcel No. 23-231-010 Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
overburden		0	3	3
Brown Hard pack Clay		3	21	18
Course obsidian Sands and Gravels and Clay Seams		21	110	89
Brown Solid Clay		110	186	76
Small Volcanic Sands Clay Seams		186	200	14
Fractured Volcanic Gravels (Hard)	xxx	200	220	20

RECEIVED 99 JAN 19 AM 8:33 STATE ENGINEER'S OFFICE

Date started 1-4, 1999
Date completed 1-8, 1999

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25	75	3 HRS

8. WELL CONSTRUCTION
Depth Drilled 220 Feet Depth Cased 220 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
10 3/4	0	220

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	220

Perforations:
Type perforation Mill Slot
Size perforation 3x3/32
From 200 feet to 220 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 55
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☑ Yes ☐ No
From 55 feet to 220 feet

9. WATER LEVEL
Static water level 70 feet below land surface
Artesian flow G.P.M. 25 P.S.I.
Water temperature Cold °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Capital City Well Drilling (Contractor)
Address 20 Kit Kat DR. (Contractor)
Carson City NV. 89706
Nevada contractor's license number issued by the State Contractor's Board 41775
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed Michael L Hack (By driller performing actual drilling on site or contractor)
Date 1-8-99

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627