#MW 108

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 73489
Permit No.
Basin 137B

NOTICE OF INTENT NO. 32833

1. OWNER ROUND MTN GOLD CORP
MAILING ADDRESS PO BOX 480
ROUND MTN NEVADA 89045

ADDRESS AT WELL LOCATION
1/4 MILE EAST OF HWY 376 INBETWEEN MILE MARKER 46 & 47 ON MINE SITE

2. LOCATION SW 1/4 SW 1/4 Sec. 26 T. 10 N/S R. 43 E. NYE County

PERMIT NO. MO 992-D
Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
GRANITE WASH & BOULDERS		0	158	158
BRN CLY & SOME GRAVEL		158	169	11
BRN CLY & GRAVEL STRINGERS		169	195	26
LARGE GRAVEL & SAND.	X	195	220	25

8. WELL CONSTRUCTION
Depth Drilled 220 Feet Depth Cased 220 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	50	Feet
8 3/4	Inches	50	Feet	220	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	+2	220

Perforations:
Type perforation MILLED
Size perforation 3 X 1/8 DOUBLE ROW
From 200 feet to 220 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout X ENVIRO PLUG
Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 130 feet below land surface
Artesian flow NO G.P.M. P.S.I.
Water temperature 80 °F Quality POOR

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WOYTEK DRILLING CO INC
Contractor
Address 2220 STOWE DR.
Contractor
RENO NEVADA 89511
Nevada contractor's license number issued by the State Contractor's Board 024521A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1442
Signed Thomas M Harris
By driller performing actual drilling on site or contractor
Date 5-6-98

Date started 5-4, 1998
Date completed 5-6, 1998

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
70+		4 HRS

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627