P-17 HWWT-5

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 73492
Permit No.
Basin 13715

NOTICE OF INTENT NO. 32834

1. OWNER Round Mtn Gold Corp
MAILING ADDRESS Po Box 480
Round Mtn. Nevada 89045

ADDRESS AT WELL LOCATION
Hadley Sewage Ponds - HWWT-5

2. LOCATION NE ¼ NW ¼ Sec. 28 T. 10 N/S R. 43 E. Nye County

PERMIT NO. W-M0680 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
This well was abandon by rigging up over well - installing 2" pipe into well mixed 15 sacks of cement 6 gal of H2O per sck - a weight of 15.2 lbs per gal cement was pumped from bottom to top 2" pipe removed - casing was cut off at ground level.				
Drilled 12-6-93				
intent # 22324				

Date started 5-1, 1998
Date completed 5-1, 1998

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 110 Feet Depth Cased 110 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
8 3/4	Inches	0 Feet	50 Feet
7 7/8	Inches	50 Feet	110 Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4	6.0	.188		

Perforations:
Type perforation Milled
Size perforation .040
From 90 feet to 110 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 90 feet below land surface
Artesian flow 5 G.P.M. — P.S.I.
Water temperature C °F Quality Poor

10. DRILLER'S CERTIFICATION
This well was ~~drilled~~ P&A under my supervision and the report is true to the best of my knowledge.

Name Woytek Drilling Co Inc (Contractor)
Address 2220 Stowe Dr (Contractor)
Reno Nevada 89511

Nevada contractor's license number issued by the State Contractor's Board 024521A

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1442

Signed Thomas M Harris
By driller performing actual drilling on site or contractor

Date 5-1-98

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627