

OFFICE USE ONLY
Log No. 73495
Permit No. 137B
Basin. 137B
NOTICE OF INTENT NO. 32838

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER GARY & BETTY REESE ADDRESS AT WELL LOCATION 13 BELL COURT
MAILING ADDRESS H.C. 65 Box 13 GILLMAN SPRINGS NEVADA
AUSTIN NEVADA 89310
2. LOCATION N.W. 1/4 NE 1/4 Sec 10 T 16 N/S R. 44 E LANDER County
PERMIT NO. 4-021-19 Parcel No. GILLMAN SPRINGS RANCH Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BROWN CLAY		0	8.3	8.3
MEDIUM SIZE GRAVEL	Y	8.3	9.0	7
GRAY CLAY		9.0	10.6	1.6
COARSE SAND		10.6	10.9	3
TAN TO WHITE CLAY		10.9	14.5	3.6
LARGE GRAVEL & SAND	X	14.5	15.6	1.1
TAN TO YELLOW CLAY		15.6	17.5	1.9
GRAVEL & CLAY MIXED		17.5	18.5	1.0
MOSTLY SMALL GRAVEL	X	18.5	20.0	1.5

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet
HOLE DIAMETER (BIT SIZE)
From To
1 1/8 Inches 0 Feet 50 Feet
3/4 Inches 50 Feet 200 Feet
Inches Feet Feet
CASING SCHEDULE
Size O.D. (Inches) Weight/Ft. (Pounds) Wall Thickness (Inches) From (Feet) To (Feet)
6 5/8 12.9 .188 72 200

Perforations:
Type perforation MILLED
Size perforation 3 1/2
From 8.0 feet to 9.0 feet
From 14.5 feet to 15.5 feet
From 18.0 feet to 20.0 feet
From feet to feet
From feet to feet
Surface Seal: Yes No Seal Type:
Depth of Seal 50 Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout
Gravel Packed: Yes No ENVIRO PLUG
From feet to feet

RECEIVED
90 SEP 22 AM 9:58
STATE ENGINEERS OFFICE

Date started 8-25 1998
Date completed 8-28 1998

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>60</u>	<u>NA</u>	<u>4 HRS</u>

9. WATER LEVEL
Static water level 22 feet below land surface
Artesian flow NO G.P.M. P.S.I.
Water temperature 62 °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WOTTEK DRILLING CO. INC. Contractor
Address 2220 STONE DRIVE Contractor
RENO NEVADA 89511
Nevada contractor's license number issued by the State Contractor's Board 024521A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1442
Signed J. Thomas M. Harris
By driller performing actual drilling on site or contractor
Date 8-27-98