

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 37934

1. OWNER STEV & NANCY GORDON ADDRESS AT WELL LOCATION 1 MI NORTH WEST OF HWY 50 AT BOB SCOTT SUMMIT
 MAILING ADDRESS 5305 PATRICIA AVE. LAS VEGAS NEVADA 89130

2. LOCATION SW 1/4 NW 1/4 Sec. 35 T 19 N/S R. 44 E LANDER County _____
 PERMIT NO. 05-450-16 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|--|--------------|-----------|------------|------------|
| <u>ALLUVIAL WITH BOLDERS</u> | | <u>0</u> | <u>12</u> | <u>12</u> |
| <u>BASALT CAP</u> | | <u>12</u> | <u>14</u> | <u>2</u> |
| <u>BLACK TO GRAY CLAY</u> | | <u>14</u> | <u>17</u> | <u>3</u> |
| <u>BOLDERS-RUBBLE & CLAY STRINGERS</u> | | <u>17</u> | <u>70</u> | <u>53</u> |
| <u>DECOMPOSE GRANITE WITH SMALL WATER BEARING FRACTURES.</u> | <u>X</u> | <u>70</u> | <u>225</u> | <u>155</u> |

8. WELL CONSTRUCTION
 Depth Drilled 225 Feet Depth Cased 225 Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|----------------------|----------------|-----------------|
| <u>10 5/8</u> Inches | <u>0</u> Feet | <u>50</u> Feet |
| <u>8 3/4</u> Inches | <u>50</u> Feet | <u>225</u> Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|------------|
| <u>6 5/8</u> | <u>12.9</u> | <u>.188</u> | <u>+2</u> | <u>225</u> |

Perforations:
 Type perforation MILLED
 Size perforation 3 x 7/8

From 164 feet to 184 feet
 From 204 feet to 225 feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 X ENVIRO PLUG

Depth of Seal 50

Placement Method: Pumped Poured

Gravel Packed: Yes No

9. WATER LEVEL
 Static water level 70 feet below land surface
 Artesian flow NO G.P.M. _____ P.S.I. _____
 Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WOYTEK DRILLING CO INC Contractor
 Address 2220 STONE DR RENO NEVADA 89511 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 024521A
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1442
 Signed Thomas M Hales By driller performing actual drilling on site or contractor
 Date 10-12-98

Date started 10-10, 1998
 Date completed 10-12, 1998

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|----------|-------------------------------|--------------|
| <u>6</u> | <u>NA</u> | <u>4 HRS</u> |