WHITE--DIVISION OF WATER RESOURCES
CANARY--CLIENT'S COPY
PINK--WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 73503
Permit No.
Basin 105

NOTICE OF INTENT NO. 33320

1. OWNER Verna Daane
MAILING ADDRESS PO Box 1755 Fallon NV 89406
ADDRESS AT WELL LOCATION 1597 US. Highway 395 Minden NV

2. LOCATION NE ¼ NW ¼ Sec. 32 T. 13 N/S R. 20 E. Douglas County
PERMIT NO. M/O 1096 (Issued by Water Resources) | 025-211-01 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Auger

6. LITHOLOGIC LOG #1

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Gravely - Sand | | 0 | 5 | 5 |
| Sand | 12 | 5 | 30 | 25 |

RECEIVED 99 JAN 12 AM 10:16 STATE ENGINEER'S OFFICE

Date started 8-24, 19 98
Date completed 8-26, 19 98

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| NA | | |

8. WELL CONSTRUCTION
Depth Drilled 30 Feet Depth Cased 30 Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 10 Inches | 0 Feet | 30 Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 4 | PVC | SCH 40 | 0 | 30 |
| | | | | |
| | | | | |

Perforations:
Type perforation Factory
Size perforation 0.20
From 10 feet to 30 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 7
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 9 feet to 30 feet

9. WATER LEVEL
Static water level 12 feet below land surface
Artesian flow NA G.P.M. NA P.S.I.
Water temperature Cold °F Quality NA

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name ANDRESEN EXPLORATION (Contractor)
Address 1635 Bedford rd (Contractor)
Reno NV 89509
Nevada contractor's license number issued by the State Contractor's Board 34525
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1028-T2
Signed (By driller performing actual drilling on site or contractor)
Date 12/25/98

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627