OH-27 A

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 73516
Permit No. 31
Basin

NOTICE OF INTENT NO.

1. OWNER AMAX Gold INC.
MAILING ADDRESS 600 Sod House RD
W. Winnemucca, NV 89445
ADDRESS AT WELL LOCATION AMAX SLEEPER MINE

2. LOCATION NW ¼ NE ¼ Sec. 17 T. 40 N/S R. 35 E. Humboldt County
PERMIT NO. (Issued by Water Resources) Parcel No. N/A Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Run Tremmie to Bottom & Pump Cement to Surface				
P&A				1ST
				2ND
				3RD

Plugging of triple Completion

Date started 8-21-97, 19
Date completed 8-21-97, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Plugging of logs	#'s	25798
		25801
		25802

8. WELL CONSTRUCTION
Depth Drilled 250 Feet Depth Cased 250 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
8 Inches	0 Feet	250 Feet
Inches	Feet	Feet
Inches	Feet	Feet

3 STRINGS OF 2 INCH PVC
CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8		.250	-1	8
2		Schedule 40	-1	205
2		"	225	232
2		"	-1	70
2		"	-1	30

Perforations:
Type perforation Slotted
Size perforation .010
From 1ST 200 feet to 205 feet
From 225 feet to 230 feet
From feet to feet
From 2ND 70 feet to 75 feet
From 3RD 30 feet to 35 feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name STACO Well SERVICES (Contractor)
Address 3359 LAST CHANCE RD (Contractor)
ELKO, NV 89801
Nevada contractor's license number issued by the State Contractor's Board 0038169
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2053
Signed (By driller performing actual drilling on site or contractor)
Date

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-027