

PW-58

WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY


STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 73521
Permit No. 31
Basin. 31

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 

1. OWNER AMAX Gold INC. ADDRESS AT WELL LOCATION AMAX Sleeper Mine
MAILING ADDRESS 600 SOD HOUSE RD WINDERMERE, NV 89445
2. LOCATION NW 1/4 SE 1/4 Sec. 16 T. 40 N. R. 35 E Humboldt County
PERMIT NO. 53227 Issued by Water Resources Parcel No. N/A Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition Domestic Irrigation Test Cable Rotary RVC
 Deepen Abandon Other..... Municipal/Industrial Monitor Stock Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Rip 2 Holes per EVERY 1' From 250 up to 60'</u>				
<u>RUN 2" Thermine Pump 10 Strength Bit @ 70' top From Bottom. Pump Current From 20' to TOP</u>				
<u>R/H</u>				

8. WELL CONSTRUCTION
Depth Drilled 530 Feet Depth Cased 511 Feet
HOLE DIAMETER (BIT SIZE)
From To
31 Inches 0 Feet 20 Feet
25 Inches 20 Feet 220 Feet
19 Inches 220 Feet 530 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>26</u>		<u>.375</u>	<u>0</u>	<u>20</u>
<u>20</u>		<u>.375</u>	<u>0</u>	<u>220</u>
<u>14</u>		<u>.250</u>	<u>0</u>	<u>259</u>

Perforations:
Type perforation SLOT, LOUVERED
Size perforation 1/8
From 259 feet to 511 feet
From.....feet to.....feet
From.....feet to.....feet
From.....feet to.....feet
From.....feet to.....feet

Surface Seal: Yes No Seal Type:
Depth of Seal..... Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout
Gravel Packed: Yes No
From.....feet to.....feet

9. WATER LEVEL
Static water level.....feet below land surface
Artesian flow..... G.P.M. P.S.I.
Water temperature.....°F Quality.....

Date started 8-22-97, 19.....
Date completed 8-22-97, 19.....

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
<u>Plugging of log #48541</u>			

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name STACO Well SERVICES Contractor
Address 3355 LAST CHANCE RD ELKO, NV 89801 Contractor
Nevada contractor's license number issued by the State Contractor's Board 0038169
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2053
Signed [Signature] By driller performing actual drilling on site or contractor
Date.....