INJ-1

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 73522
Permit No.
Basin 31

NOTICE OF INTENT NO.

1. OWNER AMAX Gold INC
MAILING ADDRESS 600 Sod House RD
WINNEMUCCA, NV 89445
ADDRESS AT WELL LOCATION AMAX Sleeper Mine

2. LOCATION NW ¼ SW ¼ Sec. 16 T. 40 (N/S) R. 35 E. Humboldt County

PERMIT NO. (Issued by Water Resources) | Parcel No. | Subdivision Name N/A

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
STATIC 174'				
Tagged Bottom @ 530'				
Ripped Two Holes per Ft From 235 up to 205' ½" X 515"				
Pump 10 Sacks Gel Foam Bottom To Surface				
Pump Cement From 30' To Surface.				
P & A.				

Date started 8-12-97, 19
Date completed 8-18-97, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Plugging of log # 28684		

8. WELL CONSTRUCTION
Depth Drilled 540 Feet Depth Cased 540 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
14 3/4	0	540

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	22.4	1250	0	240

Perforations:
Type perforation SCREEN
Size perforation 100 SLOT
From 240 feet to 540 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name STACO Well Services (Contractor)
Address 3359 Last Chance RD (Contractor)
ELKO, NV 89801
Nevada contractor's license number issued by the State Contractor's Board 0038169
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2053
Signed
By driller performing actual drilling on site or contractor
Date

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627