WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 73543
Permit No.
Basin 35
SEE LOG #9994
NOTICE OF INTENT 36857

1. OWNER U.S. BLM
MAILING ADDRESS 3900 E. IDAHO
ELKO, NV 89801
ADDRESS AT WELL LOCATION None

2. LOCATION SW ¼ SE ¼ Sec. 27 T. 44 N S R 50 E ELKO County
PERMIT NO. 52345 (Issued by Water Resources) | Unk. (Parcel No.) | Nano - Wilson Reservoir (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☑ Abandon ☐ Other

4. PROPOSED USE (Recreation)
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
8-11 Removed concrete platform. Dug down 5' & removed seal then pulled casing & covered hole waiting on cement grout availability Can tremmie pipe to bottom				
8-24 Pumped 165 bags of neat cement into hole through tremmie pipe. Needed three stages of resetting tremmie in order to complete.				

Date started Pulled casing — 8-11, 1998
Date completed Cemented hole - 8-24, 1998

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 260 Feet Depth Cased 261 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
8 Inches	0 Feet	260 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	24	.277	+1	260

Perforations:
Type perforation Mill slots
Size perforation 1/8 x 3
From feet to feet
From 200 feet to 210 feet
From 220 feet to 230 feet
From 240 feet to 255 feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 3 Ft.
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☑ Concrete Grout
Gravel Packed: ☐ Yes ☑ No
From feet to feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name MUTH DRILLING CO. (Contractor)
Address 203 PINE ST. (Contractor)
ELKO, NV 89801
Nevada contractor's license number issued by the State Contractor's Board 10819
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 632
Signed James V. Muth (By driller performing actual drilling on site or contractor)
Date 10-13-98

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627