

Log No. 73550
 Permit No. 9772A
 Basin 9772A

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 40376

1. OWNER RICHARD & ANN McNEELY ADDRESS AT WELL LOCATION 1200 Goldstone Road
 MAILING ADDRESS 7715 Hughes Drive Reno, Nevada 89506
 2. LOCATION NE 1/4 SE 1/4 Sec. 30 T. 22N N/S R. 19 E Washoe County
 PERMIT NO. 079-352-05 Issued by Water Resources Parcel No. Red Rock Estates #19 Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition Deepen Abandon Other
 4. PROPOSED USE
 Domestic Municipal/Industrial Irrigation Monitor Test Stock
 5. WELL TYPE
 Cable Rotary RVC Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Brown clay		1	15	14
Brown sandy clay		15	61	46
Soft zone (NO WATER)		61	63	2
Brown sandy clay		63	124	61
Cemented brown sandy clay		124	135	11
Gray sandy clay		135	170	35
Soft zone (app 3 GPM)	X	170	171	1
Gray sandy clay		171	220	49
Soft zone (app 2 GPM)	X	220	221	1
Gray sandy clay		221	265	44
Soft zone (app 5 GPM)	X	265	266	1
Green sandy clay		266	327	61
Gray sandy clay		327	360	33
Soft zone (NO WATER)		360	362	2
Gray sandy clay		362	430	68
Soft zone (NO WATER)		430	431	1
Black volcanic rock		431	439	8
Gray sandy clay		439	471	32
Soft zone (app 5 GPM)	X	471	492	21
Gray sandy clay		492	506	14
Softer gray sandy clay (NO WATER)		506	519	13
Gray sandy clay		519	525	6

8. WELL CONSTRUCTION
 Depth Drilled 525 Feet Depth Cased 525 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10 Inches 0 Feet 50 Feet
8 5/8 Inches 50 Feet 525 Feet
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	525

Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 3 x 5 around
 From 180 feet to 200 feet
 From 240 feet to 260 feet
 From 360 feet to 380 feet
 From 480 feet to 520 feet
 From feet to feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 feet Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 525 feet

9. WATER LEVEL
 Static water level 121 feet below land surface
 Artesian flow 15 G.P.M. 15 P.S.I.
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WAYNE DRILLING, INC. Contractor
 Address P.O. BOX 12370 Contractor
RENO, NEVADA 89510
 Nevada contractor's license number 0022549
 issued by the State Contractor's Board
 Nevada driller's license number 923 issued by the
 Division of Water Resources, the on site driller
 Signed Jerry G. Hedman
 By driller performing actual drilling on site or contractor
 Date January 11, 1999

Date started 1-4-99, 19
 Date completed 1-8-99, 19

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>15</u>		