

OFFICE USE ONLY
 Log No. 73563
 Permit No. 105
 Basin 105

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 28116

1. OWNER Ken Wood ADDRESS AT WELL LOCATION 2049 Fish Springs Rd. Gardnerville W. 89410
 MAILING ADDRESS Gardnerville W. 89410
 2. LOCATION NW 1/4 SE 1/4 Sec. 16 T. 12 S R. 21 E. Douglas County
 PERMIT NO. 35-262-030 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Overburden</u>		<u>0</u>	<u>3</u>	<u>3</u>
<u>Brown Clay</u>		<u>3</u>	<u>10</u>	<u>7</u>
<u>Coarse Sands and Gravels</u>		<u>10</u>	<u>29</u>	<u>19</u>
<u>Brown Clay</u>		<u>29</u>	<u>49</u>	<u>20</u>
<u>Gray Clay w/Black Sands</u>		<u>49</u>	<u>91</u>	<u>42</u>
<u>Gray Gummy Clay w/Black Sands</u>	<u>Water</u>	<u>91</u>	<u>163</u>	<u>72</u>
<u>Small Black Sand Spans</u>		<u>163</u>	<u>265</u>	<u>102</u>
<u>Solid Clay Gray</u>				
<u>Small Volcanic Sands</u>	<u>XX</u>	<u>265</u>	<u>300</u>	<u>35</u>

8. WELL CONSTRUCTION
 Depth Drilled 300 Feet Depth Cased 300 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 1/4 Inches To 300 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13-23</u>	<u>.188</u>	<u>0</u>	<u>300</u>

Perforations:
 Type perforation Mill Slot
 Size perforation 3 x 3/32
 From 280 feet to 300 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 100
 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 100 feet to 300 feet

9. WATER LEVEL
 Static water level 10' feet below land surface
 Artesian flow _____ G.P.M. 35 P.S.I.
 Water temperature 60.6 °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Capital City Well Drilling Contractor
 Address 20 Kit Kat Dr. Carson City NV. 89706 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 41775
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1965
 Signed Michael Hook
 By driller performing actual drilling on site or contractor
 Date 12-2-98

Date started 11/30, 1998
 Date completed 12/13, 1998

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>357</u>	<u>78</u>	<u>3 HRS</u>