WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 73564
Permit No.
Basin 105

NOTICE OF INTENT NO. 38867

1. OWNER Karen Fuentes
MAILING ADDRESS 5633 Best Well DR
SAN Jose' CA 95123

ADDRESS AT WELL LOCATION 2600 Snyder Ave
Carson City NV 89706

2. LOCATION SE ¼ SE ¼ Sec. 3 T. 14 N/S R. 20 E. Carson County
PERMIT NO. Issued by Water Resources | Parcel No. 10-491-19 | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Course DG Sands		0	60	60
Course Granite with Small Clay Ball		60	90	30
Rusty Stained DG Granite		90	120	30
Hard Blue Granite		120	132	12
Course DG Sands		132	173	41
Fractured Rusty DG Granite	xxx	173	200	29

Date started 11/28/98, 1998
Date completed 11/30, 1998

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
18-20	75	3 HRS

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 3/4 Inches	0 Feet	140 Feet
6 5/8 Inches	140 Feet	200' Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 3/8	13.03	.188	0	140
5 9/10	12.10	.188	130	200

Perforations:
Type perforation Mill Slot
Size perforation 3x3/32
From 120 feet to 140 feet
From feet to feet
From 180 feet to 200 feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 100
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 100 feet to 200' feet

9. WATER LEVEL
Static water level 10 feet below land surface
Artesian flow G.P.M. 18-20 P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Capital City Well Drilling (Contractor)
Address 20 Kit Kat DR (Contractor)
Carson City NV 89706
Nevada contractor's license number issued by the State Contractor's Board 41775
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 11/30/98

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627