

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 36579

1. OWNER Benny Schroeder ADDRESS AT WELL LOCATION _____
MAILING ADDRESS P.O. Box 635 _____
Eureka NV 89316 _____

2. LOCATION SW 1/4 SE 1/4 Sec 28 T 20 N S R 53 E Eureka County _____
PERMIT NO. 07-380-41 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil		0	2	2
Caliche		2	19	17
Cemented Gravel		19	162	143
Caliche		162	165	3
Cemented Gravel		165	193	18
gravel sand	X	193	199	6
Granite	X	199	232	33
gravel sand	X	232	263	31
Granite		263	265	2
gravel sand	X	265	272	7
Granite		272	280	8

8. WELL CONSTRUCTION
Depth Drilled 280 Feet Depth Cased 280 Feet

HOLE DIAMETER (BIT SIZE)
From _____ To _____
10 Inches 0 Feet 280 Feet
Inches _____ Feet _____ Feet
Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>		<u>198</u>	<u>0</u>	

Perforations:
Type perforation Full slot
Size perforation 1/2"

From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal 50 _____ Neat Cement
Placement Method: Pumped Poured Cement Grout Concrete Grout

Gravel Packed: Yes No
From 50 feet to 280 feet

Date started Jan 10, 1998
Date completed Jan 12, 1998

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input checked="" type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>307</u>	<u>0</u>	<u>2</u>

9. WATER LEVEL
Static water level 152 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Steve Wall Service Contractor
Address P.O. Box 10 Contractor
5110 NV

Nevada contractor's license number issued by the State Contractor's Board 0038109
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1438

Signed Sho Bennett
By driller performing actual drilling on site or contractor
Date Jan 12 - 98

RECEIVED
28 AUG - 6 AM 10:46
WATER ENGINEERING OFFICE