WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 73570
Permit No.
Basin 92B

NOTICE OF INTENT NO. 40377

1. OWNER Virginia J. Tower
MAILING ADDRESS 615 Oregon Blvd.
Reno, Nevada 89506

ADDRESS AT WELL LOCATION Same

2. LOCATION NE ¼ NW ¼ Sec. 15 T 21N N/S R 19 E Washoe County
PERMIT NO. (Issued by Water Resources) 080-404-03 (Parcel No.) Lemmon Valley (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown sand		0	3	3
Decomposed granite with clay		3	6	3
Decomposed granite		6	12	6
Weathered granite		12	18	6
Green granite		18	31	13
White clay		31	34	3
Green hard granite		34	73	39
Soft rusty granite		73	76	3
Green hard granite		76	132	56
Soft zone (NO WATER)		132	133	1
Green hard granite		133	147	14
Soft weathered granite		147	196	49
Green granite		196	246	50
Gray granite		246	292	46
Fracture granite	X	292	355	63
Gray granite		355	360	5
See also log #'s				
Dom 74375				
Orig. 39400				

Date started 12-1-98, 19
Date completed 12-3-98, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
15+		

8. WELL CONSTRUCTION
Depth Drilled 360 Feet Depth Cased 360 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	50 Feet
8 5/8 Inches		50 Feet	360 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	360

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 295 feet to 355 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50 feet
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 360 feet

9. WATER LEVEL
Static water level 272 feet below land surface
Artesian flow G.P.M. 15+ P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WAYNE DRILLING, INC. (Contractor)
Address P.O. BOX 12370 (Contractor)
RENO, NEVADA 89510

Nevada contractor's license number issued by the State Contractor's Board 0022549

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923

Signed [signature] (By driller performing actual drilling on site or contractor)
Date December 3, 1998

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627