WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 73571
Permit No. 44
Basin

NOTICE OF INTENT NO. 3[illegible]

1. OWNER ROBERT L. PENROD
MAILING ADDRESS 255 11th ST
ELKO NV 89801

ADDRESS AT WELL LOCATION

2. LOCATION SE ¼ SE ¼ Sec. 28 T. 36 N/S R. 57 E. Elko County
PERMIT NO. 73040 (Issued by Water Resources) 024-067-006 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☑ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy Clay		0	21	21
Sand w/water	vvr	21	24	3
Sand & clay streaks		24	65	41
Sand w/w	6	60	65	5
"		70	80	10
Sand & clay streaks with water in each sand zone		80	160	
Clay		160	164	
T.D. 164				

RECEIVED 98 OCT 15 AM 11:36

Date started 9-10, 1998
Date completed 9-17, 1998

7. WELL TEST DATA
TEST METHOD: ☑ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
60	15	1 hrs

8. WELL CONSTRUCTION
Depth Drilled 164 Feet Depth Cased 165 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	50 Feet
8 Inches	50 Feet	100 Feet
6 Inches	100 Feet	165 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.97	.188	+1	164

Perforations:
Type perforation Torch cut
Size perforation 1/8 x 3
From feet to feet
From 60 feet to 160 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 50 feet to ? feet

9. WATER LEVEL
Static water level 17 ft. feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Muth Drilling Co. (Contractor)
Address 203 Pine St (Contractor)
Elko, NV 89801
Nevada contractor's license number issued by the State Contractor's Board 10819
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 632
Signed James V. Muth
By driller performing actual drilling on site or contractor
Date 10-15-98

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627