WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 73581
Permit No.
Basin 101

NOTICE OF INTENT NO. 36215

1. OWNER MIKE CASEY
MAILING ADDRESS 1550 S ALLEN ROAD
FALLON, NV 89406

ADDRESS AT WELL LOCATION
5315 CALEB / Fallon

2. LOCATION SW 1/4 NE 1/4 Sec. 20 T 19 N/S R 28 E CHURCHILL County
PERMIT NO. _____ Issued by Water Resources
8-174-14 Parcel No.
Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other _____

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[X] Air [ ] Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BROWN SAND		0	15	15
BROWN CLAY		15	18	3
BLACK SAND		18	30	12
BLACK CLAY		30	40	10
GREY SAND		40	45	5
BLACK CLAY		45	50	5
BLACK SAND	X	50	64	14

RECEIVED
98 NOV -4 AM 11:09
STATE ENGINEERS OFFICE

Date started 9/28/98 , 19__
Date completed 10/3/98 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20		1 hr.

8. WELL CONSTRUCTION
Depth Drilled 63 Feet Depth Cased 63 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 3/4	Inches	0	Feet	50	Feet
6 1/4	Inches	50	Feet	64	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	+1	64

Perforations:
Type perforation MACHINE SLIT
Size perforation .080
From 58 feet to 63 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From _____ feet to _____ feet

9. WATER LEVEL
Static water level 8.5 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature COOL °F Quality UNTESTED

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Welsco Drilling Corp. (Contractor)
Address 305 E. WILLIAMS AVE. P. O. BOX 888 (Contractor)
FALLON, NV 89407

Nevada contractor's license number issued by the State Contractor's Board 11752

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1996

Signed _____ By driller performing actual drilling on-site or contractor

Date 10-31-98