WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 73582
Permit No.
Basin 101

NOTICE OF INTENT NO. 36214

1. OWNER MIKE CASEY
MAILING ADDRESS 1550 S. ALLEN ROAD
FALLON, NV 89406

Bad address
ADDRESS AT WELL LOCATION
5285 MICHELLE WAY ; Fallon
75153 1620

2. LOCATION SW 1/4 NE 1/4 Sec. 20 T 19 N/S R 28 E CHURCHILL County
PERMIT NO. Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BROWN SAND		0	15	15
BROWN CLAY		15	18	3
BROWN SAND		18	30	12
BLACK CLAY		30	40	10
GRAY SAND		40	45	5
BLACK CLAY		45	50	5
BLACK SAND	X	50	58	8

RECEIVED
98 NOV -4 AM 11:09
STATE ENGINEER'S OFFICE

8. WELL CONSTRUCTION
Depth Drilled 58 Feet Depth Cased 58 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 3/4	Inches	0	Feet	50	Feet
\6 1/8	Inches	50	Feet	58	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	+1	58

Perforations:
Type perforation MACHINE SLIT
Size perforation .080
From 52 feet to 57 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From feet to feet

9. WATER LEVEL
Static water level 8 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COOL °F Quality UNTESTED

Date started 9/24/98 , 19
Date completed 10/2/98 , 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20		1 hr.

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Welsco Drilling Corp. (Contractor)
Address 305 E. WILLIAMS AVE. P. O. BOX 888 (Contractor)
FALLON, NV 89407

Nevada contractor's license number issued by the State Contractor's Board 11752

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1996

Signed (By driller performing actual drilling on-site or contractor)

Date 10-31-98