WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 73605
Permit No.
Basin 212

NOTICE OF INTENT NO. 17990

1. OWNER Alan NOrland
MAILING ADDRESS 6854 W. Deer Springs
Las Vegas, NV 89131

ADDRESS AT WELL LOCATION Yenaya & Deer Springs
7080 Deer Springs Wy

2. LOCATION SW ¼ NE ¼ Sec. 22 T. 19 N/S R. 60 E. Clark County
PERMIT NO. Issued by Water Resources
125-22-601-007 Parcel No.
Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	3	3
Tan sandy clay w/		3	318	315
clay stringers				~~318~~
Sand & gravels		318	331	13
slight cemntation				
Tan sandy clay w/sand		331	392	61
& gravel stringers				
Coarse sand w/small		392	411	19
gravels				

Date started 10/13, 19 98
Date completed 10/23, 19 98

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 411 Feet Depth Cased 411 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
12 3/4	0	411

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
~~8 5/8~~			~~+1~~	~~311~~
"			~~331~~	~~371~~

Perforations:
Type perforation Saw cut
Size perforation 1/8"
From 311 feet to 331 feet
From 371 feet to 411 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 55'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 411 feet to 55 feet

9. WATER LEVEL
Static water level 140 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Thompson Drilling Co., Inc. Contractor
Address 7227 Hauck Street Contractor
Las Vegas, NV 89118
Nevada contractor's license number issued by the State Contractor's Board: 4286A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 1735
Signed Richard K. Thompson
By driller performing actual drilling on site or contractor
Date 10/26/98

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627