WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 73607
Permit No.
Basin 212

NOTICE OF INTENT NO. 17993

1. OWNER Gary Gibson
MAILING ADDRESS 5183 Sepulveda Blvd
Las Vegas, NV 89118

ADDRESS AT WELL LOCATION Torrey Pines & Oquendo

2. LOCATION NE ¼ NE ¼ Sec. 35 T 21 X/S R 60 E Clark County
PERMIT NO. (Issued by Water Resources) 163-35-501-028 (Parcel No.) Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Over burden | | 0 | 2 | 2 |
| Calechi | | 2 | 45 | 43 |
| Sand, gravel, boulders | | 45 | 60 | 15 |
| Gravel, sand, boulders | | 60 | 600 | 540 |

DEC 28 1998

Date started November 23, 19 98
Date completed December 22, 19 98

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 600' Feet Depth Cased 600' Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 12 1/4 Inches | 0 Feet | 600 Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 8 5/8 | | .188 | 0 | 600 |
| | | | | |

Perforations:
Type perforation 1/8 torch cut
Size perforation 1/8"
From 500 feet to 600 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 52'
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 52 feet to 600 feet

9. WATER LEVEL
Static water level 315 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature 69 °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Thompson Drilling Co., Inc. (Contractor)
Address 7227 Hauck Street (Contractor)
Las Vegas, NV 89118
Nevada contractor's license number issued by the State Contractor's Board 4286A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2074
Signed Richard K. Thompson
By driller performing actual drilling on site or contractor
Date December 23, 1998

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627

I