

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 17996

1. OWNER Curtis Leavitt ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS PO Box 36662 \_\_\_\_\_  
Las Vegas, NV 89133 \_\_\_\_\_  
 2. LOCATION NW 1/4 SW 1/4 Sec. 11 T 19 N/S R 60 E Clark County  
 PERMIT NO. 125-11-304-005 Subdivision Name \_\_\_\_\_  
 Issued by Water Resources Parcel No. \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Clay		0	50	50
Clay some cobbles		50	70	20
Caliche w/layers of clay		70	90	20
Clay		90	210	120
Cobbles		210	230	20
Sand, gravel, cobbles some clay		230	350	120
Clay		350	370	20
Clay, some sand and gravel		370	450	80

8. WELL CONSTRUCTION  
 Depth Drilled 450 Feet Depth Cased 450 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 0 To 450  
12 1/4 Inches Feet Feet  
 \_\_\_\_\_ Inches Feet Feet  
 \_\_\_\_\_ Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8		.188	+1	450

Perforations: Torch cut  
 Type perforation \_\_\_\_\_  
 Size perforation 1/8"  
 From 261 feet to 296 feet  
 From 316 feet to 351 feet  
 From 371 feet to 406 feet  
 From 426 feet to 450 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 61  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 61 feet to 450 feet

9. WATER LEVEL  
 Static water level 152 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started December 21, 1998  
 Date completed January 4, 1999

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift		
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Thompson Drilling Co., Inc. Contractor  
 Address 7227 Hauck Street Contractor  
Las Vegas, NV 89118  
 Nevada contractor's license number 4286A  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the 853 856  
 Division of Water Resources, the on-site driller.  
 Signed Richard Thompson  
 By driller performing actual drilling on site or contractor  
 Date January 8, 1999