

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 15592

1. OWNER ROBERT REEL/NANCY GERBER ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS FOREMAX ACHIEVERS 721-723 SOUTH FIRST ST.  
5700 W SAHARA AVE, #200 LAS VEGAS, NV 89102 LAS VEGAS NV 89101  
 2. LOCATION NW 1/4 SW 1/4 Sec. 34 T 20 N 61 E CLARK County  
 PERMIT NO. 139-34-310-022 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other AVLER

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
ASPHALT		0	2"	2"
FILL		2"	2.5	2.5'
BROWN CLAY		2.5	4.5	2'
GRAY CLAY		4.5	10.5	6'
CALICHE		10.5	11.5	1'
GRAY CLAY		11.5	14	2.5'
GRAVELLY CLAY		14	17	3'
CALICHE		17'	18	1'
GRAY CLAY		18'	23'	5'

8. WELL CONSTRUCTION  
 Depth Drilled 24 Feet Depth Cased 23 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From \_\_\_\_\_ To \_\_\_\_\_  
 Inches 0 Feet 1 Feet  
 Inches 1 Feet 23 Feet  
 Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:  
 Type perforation SLOTTED SCREEN  
 Size perforation .020  
 From 23 feet to 8 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 6'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 23 feet to 7 feet

9. WATER LEVEL  
 Static water level 9.8 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started JANUARY 27, 1999  
 Date completed JANUARY 27, 1999

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>N/A</u>		

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name STEVE FELKINS Contractor  
 Address 4343 S. POLARIS AVE. Contractor  
LV. NV. 89103  
 Nevada contractor's license number issued by the State Contractor's Board \_\_\_\_\_  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller, M2103  
 Signed Steve Felkins  
 By driller performing actual drilling on site or contractor  
 Date 2-1-98