WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 73620
Permit No.
Basin 212

NOTICE OF INTENT NO. 15583

1. OWNER THE CITY OF LAS VEGAS
MAILING ADDRESS 400 STEWART AVE. LV. NV. 89101

ADDRESS AT WELL LOCATION ~~N/A~~ APPROX 60' SOUTH OF SAHARA ON WESTERN AVE IN NORTH BOUND LANE.

2. LOCATION NE ¼ NW ¼ Sec. 9 T. 21 N/S R. 61 E. CLARK County
PERMIT NO. Issued by Water Resources | 162-09-100-009 Parcel No. | N/A Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other AUGER

6. LITHOLOGIC LOG B-40

Material	Water Strata	From	To	Thickness
AC OVER AGG BASE		0'	2'	2'
SANDY GRAVEL		2	3.5	1.5
GRAVELY SILT		3.5	5.0	1.5
CLAYEY SAND		5.0	10.5	5.5
SANDY GRAVEL		10.5	16.0	5.5
PARTIALY CEMENTED S&G		16.0	18.5	2.5
SANDY CLAY		18.5	28.0	9.5
CLAYEY SAND		28.0	33.0	5.0

14 JAN 2009

Date started 1-8, 1999
Date completed 1-8, 1999

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
N/A		

8. WELL CONSTRUCTION
Depth Drilled 33 Feet Depth Cased 28 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
7 Inches		0 Feet	33 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"		SCH. 40	0	28

Perforations:
Type perforation SLOTTED SCREEN
Size perforation .010
From 3 feet to 28 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 3
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 28 33 feet to 3 feet

9. WATER LEVEL
Static water level 9.25 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name STEVE FELKINS Contractor
Address 4343 S. POLARIS AVE Contractor
LV. NV. 89103
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M2103
Signed Steve Felkins By driller performing actual drilling on site or contractor
Date 1-11-99

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627