

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 15591

1. OWNER NEVADA READY MIX ADDRESS AT WELL LOCATION 601 W. BONANZA ROAD  
 MAILING ADDRESS 6610 E. Vegas Valley Dr  
LV, NV 89122

2. LOCATION SW 1/4 SW 1/4 Sec. 27 T. 20 N/S R. 61 E. CLARK County  
 PERMIT NO. N/A 139-27-401-002 NRM plant  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Auger

6. LITHOLOGIC LOG MW-7

Material	Water Strata	From	To	Thick-ness
Fill - Asphalt over base		0	1	
SANDY CLAY		1	2	
SILTY CLAY		2	7	
CLAYEY SAND		7	8	
SILTY CLAY		8	10.5	
CALICHE		10.5	11	
SANDY CLAY - w/ gravel	Y	11	14	
CALICHE	Y	14	19	
SANDY CLAY - w/ gravel	Y	19	22	
CALICHE	Y	22	24	

8. WELL CONSTRUCTION  
 Depth Drilled 24 Feet Depth Cased 24 Feet

HOLE DIAMETER (BIT SIZE)  
 From 6 1/2 Inches To 24 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2	PVC	sch 40	0	24

Perforations:  
 Type perforation slotted screen  
 Size perforation .010 inch  
 From 9 feet to 24 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Depth of Seal 7

Placement Method:  Pumped  Poured

Gravel Packed:  Yes  No  
 From 7 feet to 24 feet

Date started 1/7, 1999  
 Date completed 1/7, 1999

7. WELL TEST DATA

TEST METHOD:  Bailor  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
/		

9. WATER LEVEL  
 Static water level 12.6 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name STEVE FELKINS Contractor  
 Address 4343 S. POLARIS AVE. Contractor  
LV. NV. 89103

Nevada contractor's license number issued by the State Contractor's Board \_\_\_\_\_  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2103

Signed Steve Felkins  
 By driller performing actual drilling on site or contractor  
 Date 1-11-99