

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 15586

1. OWNER NEVADA READY MIX ADDRESS AT WELL LOCATION 421 W. BONANZA ROAD  
 MAILING ADDRESS 6610 E Vegas Valley  
LV, NV 89122

2. LOCATION SW 1/4 SW 1/4 Sec. 27 T 20 N 61 E CLARK County  
 PERMIT NO. N/A Parcel No. 139-27-401-010 Subdivision Name Louisey Const.  
 Issued by Water Resources

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Auger

6. LITHOLOGIC LOG MW-9

Material	Water Strata	From	To	Thickness
Fill-SANDY Gravel		0	1.5	
SILTY CLAY		1.5	8	
CALICHE		8	9	
CLAYEY SILT		9	12	
SANDY CLAY - w/ gravel	Y	12	14	
CALICHE	Y	14	16.5	
SANDY CLAY	Y	16.5	25	

8. WELL CONSTRUCTION  
 Depth Drilled 25 Feet Depth Cased 24 1/2 Feet

HOLE DIAMETER (BIT SIZE)  
 From 6 1/2 Inches To 2.5 Feet  
 From 0 Feet To 2.5 Feet  
 From \_\_\_\_\_ Inches To \_\_\_\_\_ Feet  
 From \_\_\_\_\_ Inches To \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2</u>	<u>PVC</u>	<u>sch 40</u>	<u>0</u>	<u>24 1/2</u>

Perforations:  
 Type perforation slotted screen  
 Size perforation .010 inch  
 From 9 1/2 feet to 24 1/2 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 8  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 8 feet to 25 feet

9. WATER LEVEL  
 Static water level 13.1 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started 1/7, 1999  
 Date completed 1/7, 1999

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
/		

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name STEVE FELKINS Contractor  
 Address 4343 S. POLARIS AVE.  
LV. NV. 89103 Contractor

Nevada contractor's license number issued by the State Contractor's Board \_\_\_\_\_  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M2103

Signed Steve Felkins  
 By driller performing actual drilling on site or contractor  
 Date 1-11-99