WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 73629
Permit No.
Basin 230

NOTICE OF INTENT NO. 17778

1. OWNER Dave + Pamela Hall
MAILING ADDRESS P.O. Box 13
Amargosa Valley, NV 89020
ADDRESS AT WELL LOCATION 172 E Anvil Rd.

2. LOCATION ¼ NW ¼ Sec. 29 T 16 N/S R 49 E NYE County
PERMIT NO. Issued by Water Resources
Parcel No. 19-171-16
Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy Clay w/lg Rock		0	83	83
Cemented Sand + Gravel		83	104	21
Sand w/ Beds of Clay		104	136	32
Sand + Gravel	1st	136	145	9
Sand, Clay + Gravel Mix		145	151	6
Sand + Gravel	2nd	151	160	9
Bottom of Well		—		

Date started Feb 3, 19 99
Date completed Feb 5, 19 99

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 160 Feet Depth Cased 160' Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10¼ Inches		0 Feet	160' Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6" PVC			0	160
Surface Protecting Casing				
6' of 8" Steel Casing		.1808	Wall	

Perforations:
Type perforation Machined
Size perforation 3" x ⅛" wrap, 12"
From 120' feet to 160' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 50 feet to 160' feet

9. WATER LEVEL
Static water level 118' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature 70 °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Cook Drilling Co. Contractor
Address HC 69 Box 452 Contractor
Amargosa Valley, NV 89020
Nevada contractor's license number issued by the State Contractor's Board 5376A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 830
Signed Dave Rau
By driller performing actual drilling on site or contractor
Date 2-6-99

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627