

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT

office use only  
Log No. 73686  
Permit No. 85  
Basin 85

NOTICE OF INTENT NO 38281  
3735 Euskara Cr

1. OWNER **Pyrenees Estates**  
MAILING ADDRESS **621 Calle De La Plata**  
**Sparks, NV 89436**

ADDRESS AT WELL LOCATION

2. Location **1/4 NW 1/4 SW Sec 27 T 21N R 21E**  
PERMIT NO. **PARCEL NO. 76-890-21**

SUBDIVISION NAME

**Washoe** County

3. WORK PERFORMED  
 New Well    Replace    Recondition  
                  Deepen    Abandon    Other

4. PROPOSED USE  
 Domestic    Irrigation    Test  
                  Municipal/Industrial    Monitor    Stock

5. WELL TYPE  
Cable     Rotary    RVC  
 Air    Other    Mud

6. LITHOLOGIC LOG				
Material	Water Strata	From	To	Thick-ness
Green red brown volcanic rock with red clay.		0	9	9
Dark green volcanic rock with orange clay.		9	58	49
Green red brown volcanic rock fractured & hard.		58	470	412
Red volcanic rock with some green & brown.		470	620	150
Tan yellow green volcanic gravel.		620	870	250
Green volcanic rock hard.		870	950	80
Tan green red volcanic rock semi hard.		950	1375	425

8. WELL CONSTRUCTION				
Depth Drilled	feet	Depth Cased	feet	
HOLE DIAMETER (BIT SIZE)				
	From	To		
	10 5/8	0	54	feet
	8 3/4	54	1200	feet
	6"	1200	1375	feet
CASING SCHEDULE				
Size O.D.	Weight/Ft.	Wall Thickness	From	To
(Inches)	(Pounds)	(Inches)	(Feet)	Feet
6 5/8	12.94	188	+1 1/2	1200
5	6.96	188	1195	1375
Perforations::				
Type Perforation	Factory			
Size perforation	3/32 x 3"			
From	1255	feet to	1275	feet
From	1305	feet to	1325	feet
From	1355	feet to	1375	feet
From		feet to		feet
From		feet to		feet
Surface Seal		<input checked="" type="checkbox"/> YES	No	Seal Type:
Depth of Seal		54	feet	Neat Cement
				Pumped
				Cement Grout
		<input checked="" type="checkbox"/> Poured		<input checked="" type="checkbox"/> Concrete Grout
Gravel Packed:		Yes	<input checked="" type="checkbox"/> No	
From		feet to	feet	

9. WATER LEVEL  
Static water level **1225** feet below land surface  
Artesian flow **0** GPM **0** P.S.I.  
Water Temperature **cold** Degrees F    Quality

Date started **12-24 -97**  
Date completed **12-23 -98**

7. WELL TEST DATA			
TEST METHOD:	Bailer	Pump	x Air Lift
G.P.M.	Draw Down (Feet Below Static)		Time (hours)
15	145		6

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name **McKay Drilling, Inc.**  
**2290 Pioneer Drive**  
**Reno, NV 89509**  
NV Contractors No. **14170**  
NV Driller's Lic (on site) **1511**  
Signed *Steve McKay*  
By driller performing actual drilling on site or contractor  
Date **12-28 -98**

RECEIVED  
98 DEC 31 AM 9:36  
STATE ENGINEERS OFFICE