

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 36617

1. OWNER Travis Geerber ADDRESS AT WELL LOCATION Blk m lot 8
 MAILING ADDRESS 135 Spring Creek Ct
Elko NV 89801

2. LOCATION NE 1/4 SE 1/4 Sec 17 T. 34 N/S R. SE E Elko County
 PERMIT NO. 013-033-008 Parcel No. LAST Chance Ranchos Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Loam		0	2	2
Dark Brown Clay		2	51	49
Light Brown Clay		51	82	31
Light Gray Clay		82	112	30
Blue Clay		112	170	58
Black Loose Sand	X	170	172	2
Black shale		172	260	78
Brown shale		260	274	14
Factor Black Shale	X	274	300	26

8. WELL CONSTRUCTION
 Depth Drilled 300 Feet Depth Cased 300 Feet

HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 300 Feet
 Inches Feet Feet
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/4</u>	<u>12.92</u>	<u>1 5/8</u>	<u>+2</u>	<u>300</u>

Perforations:
 Type perforation mill slot
 Size perforation 3/16 x 1 3/4"
 From 280 feet to 300 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 53 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 53 feet to 300 feet

9. WATER LEVEL
 Static water level 120 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality _____

Date started 7-19 1998
 Date completed 7-26 1998

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Apex</u>	<u>15</u>		<u>6.5</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name FERTIG Drilling Co Contractor
 Address P.O. Box 525 Contractor
Elko NV 89803

Nevada contractor's license number issued by the State Contractor's Board 0031904
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584

Signed 8-10-98 Shoultz
 By driller performing actual drilling on site or contractor
 Date 8-10-98