

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 36554

1. OWNER SUSAN & CHARLES PERKINS ADDRESS AT WELL LOCATION PILOT PEAK Rd
 MAILING ADDRESS P.O. Box 2369
WENDOVER, NV 89883

2. LOCATION SE 1/4 SW 1/4 NE 33 1/4 Sec. 33 T. 38 N S R. 69 E EIKO County
 PERMIT NO. 016-570-006 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CLAY / ROCK		0	12	12
CLAY		12	68	56
BOWLERS		68	78	10
CLAY		78	81	3
BOWLERS		81	84	3
CLAY HARD PAN		84	160	74
BOWLERS	X	160	171	11
CLAY		171	179	8
Bowl Dens	X	179	192	13

8. WELL CONSTRUCTION
 Depth Drilled 192 Feet Depth Cased 192 Feet

HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 192 Feet
 Inches _____ Feet _____ Feet
 Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.92</u>	<u>188</u>	<u>±2</u>	<u>192</u>

Perforations:
 Type perforation MILL SLOT
 Size perforation 3/16 X 3"
 From 172 feet to 192 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal ±0 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 60 feet to 192 feet

9. WATER LEVEL
 Static water level 112 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality _____

Date started 6-21 1998
 Date completed 6-22 1998

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Approx</u>	<u>60</u>		<u>3.5</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name FERTIG DRILLING Contractor
 Address P.O. Box 525 Contractor
EIKO, NV 89803

Nevada contractor's license number issued by the State Contractor's Board 0031904
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584

Signed Shovel C Fertig
 By driller performing actual drilling on site or contractor
 Date 7-1-98