

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 36546

1. OWNER Sherri Palmer ADDRESS AT WELL LOCATION Lot 1 Blk 24
MAILING ADDRESS 303-12 Ryndon
Elko NV 89801

2. LOCATION NE 1/4 NE 1/4 Sec. 1 T 35 R 56 E Elko County
PERMIT NO. 030-024-001 Parcel No. Ryndon Subdivision Name MUR # 1
Issued by Water Resources

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY		0	20	20
HARD SANDSTONE		20	30	10
SOFT SANDSTONE MIX CLAY		30	51	21
HARD SANDSTONE		51	79	27
CLAY		79	110	42
SOFT SANDSTONE	X	110	112	2
CLAY		112	155	43
SOFT SANDSTONE	X	155	160	5
CLAY		160	165	5
SOFT SANDSTONE	X	165	180	15

RECEIVED
90 MAY 15 AM 10:30
STATE ENGINEERING OFFICE

8. WELL CONSTRUCTION
Depth Drilled 180 Feet Depth Cased 180 Feet

HOLE DIAMETER (BIT SIZE)
From 10 1/2 Inches To 0 Feet 180 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/4</u>	<u>12.92</u>	<u>1.88</u>	<u>71</u>	<u>180</u>

Perforations:
Type perforation mill slats
Size perforation 3/16 x 3"
From 120 feet to 180 feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal 54 Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
From 54 feet to 180 feet

9. WATER LEVEL
Static water level 5 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature cold °F Quality _____

Date started 4-17, 1998
Date completed 4-23, 1998

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>25</u>	<u>4.5</u>	<u>4.5</u>

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name FERTIG Drilling Co Contractor
Address P.O. BOX 525 Contractor
Elko NV 89803
Nevada contractor's license number issued by the State Contractor's Board 0031904
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1554
Signed Shaulc Fertig Jr
By driller performing actual drilling on site or contractor
Date 5-12-98