WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 73730
Permit No.
Basin 212

NOTICE OF INTENT NO. 15098

1. OWNER Atladia Design
MAILING ADDRESS 3400 Las Vegas Blvd So ~~Las Vegas B~~ Las Vegas Nev. 89109
ADDRESS AT WELL LOCATION ~3600 Las Vegas Blvd So. West Side of Road

2. LOCATION NE ¼ NE ¼ Sec. 20 T. 21 N/S R. 61 E. Clark County County
PERMIT NO. _____ Issued by Water Resources | 160-20-501-001 Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Fill ~~Fill~~ AC Agg. Base		0	1	1
Silty Sand		1	2	1
Gravelly Sand		2	6	4
Sandy Clay		6	8	2
Caliche		8	12	4
Sandy Clay		12	13½	1½
Caliche		13½	14	½
Clayey Gravel		14	16	2
Caliche		16	17½	1½
Sandy Clay	wet	17½	21	3½
Caliche		21	27	6
Gravelly Clay		27	32	5
Silty Sand		32	35	3
Sandy Gravel		35	39	4
Sandy Clay		39	47½	8½
Silty Clay		47½	57½	10
Sandy Clay		57½	73	15½
Silty Sand		73	74	1
Sandy Clay		74	80	6

JAN 11 1999

Date started 8-11, 1997
Date completed 8-11, 1997

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 80 Feet Depth Cased 60 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
6 Inches	0 Feet	80 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
1		Sch 80 PVC	0	60
1		Sch 80 PVC	0	24

Perforations:
Type perforation Factory Slots
Size perforation .020
From 50 feet to 55 feet
From 19 feet to 24 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 10
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout Bentonite

Gravel Packed: ☒ Yes ☐ No
From 50 to 60 & 10 to 20 feet to 24 feet

9. WATER LEVEL
Static water level 19 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Terracon Consultants
Contractor
Address 4343 So. Polaris Ave.
Contractor
Las Vegas Nv 89103
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1944
Signed Thomas H. Beall
By driller performing actual drilling on site or contractor
Date 8-30-97

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627