WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 73731
Permit No.
Basin 212

NOTICE OF INTENT NO. 15098

1. OWNER Atlandia Design
MAILING ADDRESS 3400 Las Vegas Blvd So. Las Vegas NV 89109
ADDRESS AT WELL LOCATION 3600 Las Vegas Blvd So. Cut Road

2. LOCATION NE ¼ NE ¼ Sec. 20 T. 21 N/S R. 61 E. Clark County
PERMIT NO. ..... Issued by Water Resources | 160-20-501-001 Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Fill-A/C Agg base		0	2	2
Gypsum "		2	4	2
Sandy Gravel		4	6	2
Caliche		6	7	1
Sandy Gravel		7	8	1
Caliche		8	10½	2½
Silty Sand		10½	12	1½
Caliche		12	16½	4½
Sandy Gravel		16½	18	1½
Caliche		18	19	1
Sandy Clay		19	23½	4½
Caliche		23½	25	1½
Sandy Clay		25	26½	1½
Caliche		26½	29	2½
Sandy Clay		29	36	7
Caliche		36	37	1
Sandy Clay		37	40	3
Clay Gravel		40	42	2
Silty Clay		42	50	8

DCN Received JAN 14 1999

Date started 8-6, 1997
Date completed 8-6, 1997

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 50 Feet Depth Cased 50 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
6 Inches		0 Feet	50 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
1		Sch 80 PVC	0	15
1		Sch 80 PVC	0	50

Perforations:
Type perforation Factory Slots
Size perforation 020
From 10 feet to 15 feet
From 40 feet to 50 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 9
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout Bentonite

Gravel Packed: ☒ Yes ☐ No
From 39-50 feet to ..... feet

9. WATER LEVEL
Static water level 15.0 feet below land surface
Artesian flow ..... G.P.M. ..... P.S.I.
Water temperature ..... °F Quality .....

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Terracon Consultants (Contractor)
Address 4343 So Polaris Ave. (Contractor)
Las Vegas NV 89103
Nevada contractor's license number issued by the State Contractor's Board .....
Nevada driller's license number issued by the Division of Water Resources, the on-site driller Miguel
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 8-30-97

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 1-91) (O-627)