WHITE—DIVISION OF WATER RESOURCES
GANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 73732
Permit No.
Basin 212

NOTICE OF INTENT NO. 15098

1. OWNER Atlandia Design
MAILING ADDRESS 3400 Las Vegas Blvd So. Las Vegas Nv. 89109
ADDRESS AT WELL LOCATION 3600 Las Vegas Blvd So. East Side of Road

2. LOCATION NE ¼ NE ¼ Sec. 20 T. 21 N/S R. 61 E. Clark County
PERMIT NO. ____ Issued by Water Resources | Parcel No. 160-20-501-00 | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy Clay		0	5½	5½
Gravelly Clay		5½	10	4½
Sandy Gravel		10	11	1
Caliche		11	16	5
Clayey Gravel		16	17½	1½
Sandy ~~Gravel~~ Clay	wet	17½	24½	7
Caliche		24½	25	½
Sandy Clay		25	26	1
Caliche		26	27½	1½
Silty Clay		27½	33	5½
Sandy Clay		33	43½	10½
Clayey Gravel		43½	47½	4
Silty Clay		47½	49	1½
Gravelly Clay		49	54	5
Sandy Gravel	wet	54	59	5
Gravelly Clay		59	62½	3½
Sandy Clay		62½	71½	9
Silty Clay		71½	77½	6
Silty Sand	wet	77½	80	2½

JAN 1 1999

Date started 8-14, 1997
Date completed 8-14, 1997

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 80 Feet Depth Cased 55 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
6 Inches	0 Feet	80 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
1		Sch 80 PVC	0	25
1		Sch 80 PVC	0	55

Perforations:
Type perforation Factory Slot Si
Size perforation .020
From 20 feet to 25 feet
From 45 feet to 55 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 19
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout Bentonite
Gravel Packed: ☒ Yes ☐ No
From 19-25 and 44-55 feet to feet

9. WATER LEVEL
Static water level 19.6 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Terracon Consultants
Contractor
Address 4343 So. Polaris Ave.
Contractor
Las Vegas Nv 89103
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1945
Signed [signature]
By driller performing actual drilling on site or contractor
Date 8-30-97

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627