WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 73735
Permit No.
Basin 179

NOTICE OF INTENT NO. 18268

1. OWNER: CITY OF ELY PUBLIC WORKS
MAILING ADDRESS: 501 MILL ST. ELY, NV 89301
ADDRESS AT WELL LOCATION: CITY OF ELY LANDFILL

2. LOCATION: NW ¼ SW ¼ Sec. 10 T. 16 N R. 63 E. WHITE PINE County
PERMIT NO. (Issued by Water Resources) 2-028-12 (Parcel No.) Subdivision Name

3. WORK PERFORMED: [X] New Well [ ] Replace [ ] Recondition [ ] Deepen [ ] Abandon [ ] Other
4. PROPOSED USE G-3: [ ] Domestic [ ] Irrigation [ ] Test [ ] Municipal/Industrial [X] Monitor [ ] Stock
5. WELL TYPE: [ ] Cable [ ] Rotary [ ] RVC [ ] Air [X] Other AUGER

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
GRAVELLY SILT		0	74	74

DCNR/DWR Received JAN 20 1999 LAS VEGAS OFFICE

Date started 10/8, 1998
Date completed 10/8, 1998

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION — NESTED WELL
Depth Drilled 74 Feet Depth Cased 24, 54, 74 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
8 Inches	0 Feet	74 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
1.66	0.43	0.14	0	24
1.66	0.43	0.14	0	54
1.66	0.43	0.14	0	74

Perforations:
Type perforation: FACTORY SLOTTED PVC
Size perforation: 0.010"
From 19 feet to 24 feet
From 49 feet to 54 feet
From 69 feet to 74 feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 0-1 FEET
Placement Method: [ ] Pumped BENTONITE [X] Poured FROM 16-18', 46-48', 66-68'
Gravel Packed: [X] Yes [ ] No
From 18-24, 48-54, ~~feet to~~ AND 68-74 feet
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

9. WATER LEVEL
Static water level NA feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name TOM HIGH C/O CONVERSE (Contractor)
Address 731 PILOT ROAD, SUITE H (Contractor)
LAS VEGAS, NV 89119
Nevada contractor's license number issued by the State Contractor's Board 0034757
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1869
Signed (By driller performing actual drilling on site or contractor)
Date 1/21/99

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627