

OFFICE USE ONLY
 Log No. 737169
 Permit No. 49
 Basin
 NOTICE OF INTENT NO. 3900

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER SHERT PALMER ADDRESS AT WELL LOCATION LOT 1, BLOCK 24
 MAILING ADDRESS 303-12 RYNDON EIKO, NV 89801
 2. LOCATION NE 1/4 NE 1/4 Sec. 1 T 35 S R 56 E EIKO County
 PERMIT NO. 030-024-001 Parcel No. RYNDON Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY		0	20	20
HARD SANDSTONE		20	30	10
SOFT SANDSTONE MIX CLAY		30	51	21
HARD SANDSTONE		51	78	27
CLAY		78	110	42
SOFT SANDSTONE	X	110	112	2
CLAY		112	155	43
SOFT SANDSTONE	X	155	160	5
CLAY		160	165	5
SOFT SANDSTONE	X	165	180	15
HARD SANDSTONE	X	180	217	37

8. WELL CONSTRUCTION
 Depth Drilled Feet Depth Cased Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 0 Feet 217 Feet
 Inches Feet Feet
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.92</u>	<u>1.88</u>	<u>+1</u>	<u>217</u>

Perforations:
 Type perforation MUD SLOT
 Size perforation 3/16" x 3"
 From 197 feet to 217 feet
 From feet to feet
 From feet to feet
 From feet to feet
 From feet to feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 58 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 58 feet to 217 feet

9. WATER LEVEL
 Static water level 1' feet below land surface
 Artesian flow G.P.M. P.S.I.
 Water temperature Cold °F Quality

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name FERTIG DRILLING CO Contractor
 Address P.O. Box 525 Contractor
EIKO, NV 89805
 Nevada contractor's license number issued by the State Contractor's Board 0031904
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584
 Signed Shoul Fertig
 By driller performing actual drilling on site or contractor
 Date 9-8-98

Date started 8-20 1998
 Date completed 8-21 1998

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>APROX</u>	<u>45</u>	<u> </u>	<u>3</u>

RECEIVED
 08 SEP 18 AM 11:19
 STATE ENGINEERS OFFICE