WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 73774
Permit No.
Basin 44

NOTICE OF INTENT NO. 39096

1. OWNER: DEAN BECKER
MAILING ADDRESS: P.O. BOX 164, ELKO, NV
ADDRESS AT WELL LOCATION: LOT 3, BLOCK 8

2. LOCATION: SW ¼ NE ¼ Sec. 11 T. 35 (N)/S R. 54 E. ELKO County
PERMIT NO. (Issued by Water Resources) 005-52C-012 (Parcel No.) ADOBE RANCHOS (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
LOAM		0	3	3
GRAVEL		3	7	4
CLAY		7	9	2
GRAVEL		9	12	3
CEMENTED GRAVEL		12	60	48
RED SANDSTONE		60	64	4
GRAY CLAY		64	69	5
LIGHT BROWN SANDSTONE		69	74	5
BLACK SHALE		74	89	15
BROWN ROCK		89	90	1
LIGHT TAN CLAY		90	128	38
BLACK SHALE		128	172	44
LIGHT TAN CLAY		172	201	29
BLACK SHALE		201	224	23
TAN SANDSTONE		224	249	25
SOFT SANDSTONE	X	249	250	1
CLAY		250	276	26
SOFT SANDSTONE	X	276	279	3
CLAY		279	292	13

RECEIVED 98 SEP 21 AM 11:13 STATE ENGINEER'S OFFICE

Date started 9-1, 19 98
Date completed 9-3, 19 98

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
APPROX	20		3.5

8. WELL CONSTRUCTION
Depth Drilled 292 Feet Depth Cased 292 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
10 5/8	0	[illegible]
10 5/8	0	292

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	18.92	.188	+2	298

Perforations:
Type perforation: Mill slot
Size perforation: 3/16 x 3"
From 259 feet to 292 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 292 feet

9. WATER LEVEL
Static water level 150 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name (Contractor) FERTIG DRILLING CO
Address (Contractor) P.O. BOX 525, ELKO NV 89803
Nevada contractor's license number issued by the State Contractor's Board 0031904
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584
Signed (By driller performing actual drilling on site or contractor)
Date 9-8-98

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627