

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 18610

1. OWNER Glendale Service Inc. ADDRESS AT WELL LOCATION 2300 Glendale Blvd  
 MAILING ADDRESS 2300 Glendale Blvd Glendale, Nevada  
 LOCATION 1/4 NE 1/4 Sec. 7-170-014 N/S R. 166 E. Clark County  
 PERMIT NO. MO-2536A Issued by Water Resources 090-170-010 Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  New Well  Replace  Recondition  Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  Domestic  Irrigation  Test  Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  Cable  Rotary  RVC  Air  Other HSA

6. LITHOLOGIC LOG

| Material  | Water Strata | From      | To        | Thickness |
|---|--------------|-----------|-----------|-----------|
| <u>Silt/clay reddish brown, moist</u>   |              | <u>0</u>  | <u>5</u>  |           |
| <u>increased clay content increase moisture content - close to saturated conditions</u> |              | <u>5</u>  | <u>10</u> |           |
| <u>Clay silt, reddish brown, wet, mod plastic</u>                                       |              | <u>10</u> | <u>13</u> |           |
| <u>gravel lenses in dark reddish brown clay</u>   |              | <u>13</u> | <u>18</u> |           |
| <u>gravel and clay, gray moist and saturated</u>  |              | <u>18</u> | <u>20</u> |           |
| <u>Sand, gravel &amp; silt gray, saturated</u>  |              | <u>20</u> | <u>30</u> |           |

8. WELL CONSTRUCTION  
 Depth Drilled 30 Feet Depth Cased 25 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 12 Inches To 0 Feet 30 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| <u>4 1/2</u>       |                     |                         | <u>0</u>    | <u>25</u> |

Perforations:  
 Type perforation 50x40  
 Size perforation 070  
 From 25 feet to 30 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  Neat Cement  Cement Grout  Concrete Grout  
 Depth of Seal 20  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 20 feet to 30 feet

Date started 1-26-99  
 Date completed 1-26-99

7. WELL TEST DATA

| TEST METHOD: | Bailer                        | Pump         | Air Lift |
|--------------|-------------------------------|--------------|----------|
| G.P.M.       | Draw Down (Feet Below Static) | Time (Hours) |          |
|              |                               |              |          |
|              |                               |              |          |
|              |                               |              |          |

9. WATER LEVEL  
 Static water level 19 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature 84 Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name The Verde Companies, Inc. Contractor  
 Address 201 W. Deer Valley Road #7 Contractor  
Phoenix, Arizona 85027  
 Nevada contractor's license number 41809 issued by the State Contractor's Board  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M2070  
 Signed John M. Mark  
 By driller performing actual drilling on site or contractor  
 Date February 5, 1999