

OFFICE USE ONLY  
 Log No. 73812  
 Permit No. \_\_\_\_\_  
 Basin 102  
 NOTICE OF INTENT NO 35069

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Fandy W. Wisnart ADDRESS AT WELL LOCATION 17310 Cibola St  
 MAILING ADDRESS Conover city  
 2. LOCATION SE 1/4 NW 1/4 Sec 13 T 17 N/S R 24 E County Yuma  
 PERMIT NO. \_\_\_\_\_ Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Gravel</u>		<u>1</u>	<u>83</u>	
<u>Clay Blown</u>		<u>83</u>	<u>146</u>	
<u>Blow Sand</u>		<u>146</u>	<u>183</u>	
<u>Gravel</u>		<u>183</u>	<u>208</u>	
<u>Shell</u>	<u>278</u>	<u>208</u>	<u>308</u>	
<u>Fractured</u>	<u>308</u>			

8. WELL CONSTRUCTION  
 Depth Drilled 308 Feet Depth Cased 308 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
1 1/8 Inches 1 Feet 75 Feet  
8 3/4 Inches 75 Feet 308 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE  

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>1 1/8</u>	<u>13</u>	<u>1.88</u>	<u>1</u>	<u>308</u>

 Perforations:  
 Type perforation Mill Perfor  
 Size perforation 3/16 to 1/4  
 From 290 feet to 295 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 75+  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

RECEIVED  
 90 SEP 14 AM 11:58  
 STATE ENGINEERS OFFICE

Date started 8/13/98 19\_\_\_\_\_  
 Date completed 8/15/98 19\_\_\_\_\_  
 7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>6</u>	<u>2 1/2</u>	

9. WATER LEVEL  
 Static water level 182 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature 62 °F Quality Good  
 10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Jean Drill Inc Contractor  
 Address PO Box 298 Contractor  
33 NW 82448  
 Nevada contractor's license number issued by the State Contractor's Board 003184  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 820 1876  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 9/2/98