WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 73885
Permit No.
Basin 212

NOTICE OF INTENT NO. 18198

1. OWNER Nellis Air Force Base
MAILING ADDRESS RFI BLDG 245 Nellis Air Force Base, Nevada
ADDRESS AT WELL LOCATION Same

2. LOCATION NW ¼ NE ¼ Sec. 9 T. 20 N/S R. 62 E. Clark County
PERMIT NO. (Issued by Water Resources) Parcel No. 140-09-101-001 Subdivision Name

3. WORK PERFORMED: [X] New Well [ ] Replace [ ] Recondition [ ] Deepen [ ] Abandon [ ] Other
4. PROPOSED USE: [ ] Domestic [ ] Irrigation [ ] Test [ ] Municipal/Industrial [X] Monitor [ ] Stock
5. WELL TYPE: [ ] Cable [ ] Rotary [ ] RVC [ ] Air [X] Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy clay w/ gravels w/ loose non-cemented, dry tan course gravels		0	5	
Clay med stiff, med plastic moist, tan, no odor PHC		5	10	
Clay w/ gravels w/ loose non-cemented, dry		10	12	
Clay, med-stiff, med plastic, dry, tan, no odor		12	15	
Clay-same as above		15	20	
Clay - same as above		20	25	
Clay - same as above no odor PHC		25	30	
Clay - same as above, slightly moist to moist no odor PHC		30	35	
Saturated		35	37	
Clay, very moist, same as above, no odor PHC		37	44.5	

Date started 12-8, 19 99
Date completed 12-8, 19 99

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 45 Feet Depth Cased 35 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
8	0	45

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"			0	35

Perforations:
Type perforation Sch 40 PVC
Size perforation .020
From 35 feet to 45 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 31
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout
Gravel Packed: [X] Yes [ ] No
From 31 feet to 45 feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name The Verde Companies, Inc. (Contractor)
Address 301 West Deer Valley #7 Phoenix, Arizona 85027 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 41809
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M2070
Signed John Stanley
By driller performing actual drilling on site or contractor
Date 1/13/99

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627