

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
 Log/No. 73895
 Permit No. 61
 Basin

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

NOTICE OF INTENT NO. 39233

1. OWNER BARRICK GOLDSTRIKE MINES ADDRESS AT WELL LOCATION BARRICK GOLDSTRIKE MINESITE, NORTH OF CARLIN, NV.
 MAILING ADDRESS P.O. BOX 29
ELKO, NV 89803

2. LOCATION NE 1/4 NE 1/4 Sec. 30 T. 36 N. S. R. 50 E. EUREKA County
 PERMIT NO. 61407 Issued by Water Resources Parcel No. N/A Subdivision Name N/A

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Municipal (Industrial) Irrigation Test Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|--------------------|--------------|------|------|-----------|
| CARLIN FORMATION | | 0 | 445 | 445 |
| BLACK CLAY | | 445 | 465 | 20 |
| GRAY CLAY/GRAVEL | | 465 | 480 | 15 |
| BLACK GRAY CLAY | | 480 | | |
| ROCK | | | 500 | 20 |
| LIGHT GRAY GRANITE | | 500 | | |
| SOME CLAY ZONES | | | 815 | 315 |
| BLACK ROCK | | 815 | 980 | 65 |
| BLACK CLAY | | 980 | 1000 | 20 |
| LIGHT GRAY GRANITE | | 1000 | | |
| CLAY | | | 1110 | 110 |

8. WELL CONSTRUCTION
 Depth Drilled 1110 Feet Depth Cased 1098 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
20 Inches 0 Feet 35 Feet
12.25 Inches 35 Feet 1110 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| 14 | 36.71 | .250 | 0 | 30 |
| 6.625 | 17.02 | .250 | +2 | 1098 |

Perforations:
 Type perforation LOUVERED
 Size perforation .125
 From 1.18 feet to 1098 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 1.00 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 1.00 feet to 1110 feet

9. WATER LEVEL
 Static water level 754.9 feet below land surface
 Artesian flow N/A G.P.M. _____ P.S.I.
 Water temperature WARM °F Quality FAIR

Date started NOVEMBER 10 1998
 Date completed NOVEMBER 25 1998

7. WELL TEST DATA

| TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift | | | |
|---|-------------------------------|--------------|--|
| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) | |
| 51 | 36 | 1 | |

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name LANG EXPLORATORY DRILLING Contractor
 Address P.O. BOX 5279 Contractor
ELKO, NV 89802
 Nevada contractor's license number issued by the State Contractor's Board 0021976
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2085
 Signed Wan Kohlman
 By driller performing actual drilling on site or contractor
 Date DECEMBER 1, 1998