WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 73902
Permit No.
Basin 107

NOTICE OF INTENT NO. 37998

1. OWNER SMITH VALLEY CLINIC
MAILING ADDRESS 445 STATE RTE 338
SMITH, NV 89430

ADDRESS AT WELL LOCATION
445 STATE RTE 338 SMITH, NEVADA 89430

2. LOCATION NW 1/4 SW 1/4 Sec. 17 T 10 N/S R 24 E LYON County
PERMIT NO. 62992 (Issued by Water Resources) | 10-741-35 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL		0	6	6
COBBLES		6	76	70
CLAY		76	95	19
SAND & GRAVEL		95	136	41
COBBLES		136	205	69

Date started 9/15/98, 19__
Date completed 9/16/98, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
45		2 hr.

8. WELL CONSTRUCTION
Depth Drilled 256 Feet Depth Cased 250 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12-7/8 Inches		0 Feet	256 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8-5/8		.188	+1	250

Perforations:
Type perforation SINGLE ROW MILL SLOT
Size perforation 1/8 X 3
From 210 feet to 250 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 60
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 60 feet to 256 feet

9. WATER LEVEL
Static water level 145 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COOL °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Humboldt Drilling & Pump Co., Inc. (Contractor)
Address 4675 W. Winnemucca Blvd (Contractor)
Winnemucca, NV 89445

Nevada contractor's license number issued by the State Contractor's Board 015234

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2019 1562

Signed [signature] (By driller performing actual drilling on-site or contractor)

Date 10-19-98