

OFFICE USE ONLY
 Log No. 73956
 Permit No. _____
 Basin # 16

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 32279

1. OWNER Tom Airheart ADDRESS AT WELL LOCATION 1005 YONNIE LANE
 MAILING ADDRESS HERMESA, NV

2. LOCATION S/NE 1/4 NW 1/4 Sec. 22 T. 20 N/S R. 25 E. Lyon County
 PERMIT NO. 21-343-17

Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other nd

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Sand</u>		<u>0</u>	<u>6</u>	
<u>Gray clay</u>		<u>6</u>	<u>110</u>	
<u>Gravel</u>	<input checked="" type="checkbox"/>	<u>110</u>	<u>120</u>	

8. WELL CONSTRUCTION
 Depth Drilled 120 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 120 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>1300</u>	<u>3/16</u>	<u>+1</u>	<u>120</u>

Perforations:
 Type perforation full slot
 Size perforation _____
 From 100 feet to 120 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 6.50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 120 feet

9. WATER LEVEL
 Static water level: 60 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started 4-20, 1998
 Date completed 4-21, 1998

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>677</u>	<u>30</u>	

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Joseph Pulling Inc Contractor
 Address PO Box 599 Contractor
Silver Springs NV 89429
 Nevada contractor's license number 0031841
 issued by the State Contractor's Board.
 Nevada driller's license number issued by the Division of Water Resources the on-site driller
 Signed Joseph Pulling
 By driller performing actual drilling on site or contractor
 Date 4-22-98

RECEIVED
 18 MAY 21 AM 10:51
 STATE ENGINEERING OFFICE

