

OFFICE USE ONLY  
 Log No. 73967  
 Permit No. 102  
 Basin.

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 35180  
 3525 5th St

1. OWNER Craig Beverly Thurman ADDRESS AT WELL LOCATION 3525 5th St  
 MAILING ADDRESS 3525 5th St Silver Springs  
 2. LOCATION NW 1/4 NE 1/4 Sec. 16 T. 17 N/S R. 25 E County Ogden  
 PERMIT NO. 17-361-10 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVG  
 Air  Other Mod

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	30	
Shale Clay		30	46	
Gravel		46	83	
Clay		83	110	
Sand		110	163	
Clay		163	170	
Coarse Sand	✓	170	180	
Gravel				

8. WELL CONSTRUCTION  
 Depth Drilled 180 Feet Depth Cased 18 Feet

HOLE DIAMETER (BIT SIZE)  
 From 10 5/8 Inches To 180 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>	<u>13</u>	<u>1.58</u>	<u>1-180</u>	

RECEIVED  
 18 JUN 10 AM 9:59  
 STATE ENGINEERS OFFICE

Perforations:  
 Type perforation Mill Per  
 Size perforation 3AL x B x 6"  
 From 170 feet to 180 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 60  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 60 feet to 180 feet

9. WATER LEVEL  
 Static water level 33' feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality Good

Date started 6/13/98, 19\_\_\_\_  
 Date completed 6/16/98, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>60</u>	<u>35/4</u>	

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Tom Diney Jr Contractor  
 Address PO 299 Contractor  
SS NV 82429

Nevada contractor's license number issued by the State Contractor's Board 0031841  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1870

Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 6/9/98