

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 73974  
 Permit No. 104  
 Basin 104

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 30024

1. OWNER Carson City Utilities ADDRESS AT WELL LOCATION 919 Beverley Dr.  
 MAILING ADDRESS 3505 Butti Way Carson City, NV. 89701  
 2. LOCATION 1/4 Sec. 8 T. 15 N/S R. 20 E Carson City County  
 PERMIT NO. 47705 Issued by Water Resources 2-121-06 Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Measured depth of 12" well to 258.7'. Installed sand bailer and bailed well to a depth of 265.3'. Could not retrieve anymore fill from well. Removed bailer and installed 12" Mills knife. Perforated casing from a depth of 44' to 94'. Averaged 3 slots per foot. The following day, we installed tremme pipe to bottom of well and pumped in approximately 9 cubic yards of neat cement. The gravel pack between the 12" production casing and the 20" conductor casing was down to a depth of 13'. We filled the annulus with cement also.				
Static water level was measured at 24'				
Original log attached				

8. WELL CONSTRUCTION  
 Depth Drilled 267' Feet Depth Cased 267' Feet  
 HOLE DIAMETER (BIT SIZE)  
 From \_\_\_\_\_ To \_\_\_\_\_  
 Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
12"		.375		

Perforations:  
 Type perforation Mills Knife  
 Size perforation 1" long X 1/2" wide  
 From 44' feet to 94' feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Depth of Seal \_\_\_\_\_  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 24' feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Carson Pump Contractor  
 Address 1401 North Roop St. Contractor  
Carson City, NV. 89701  
 Nevada contractor's license number issued by the State Contractor's Board 39920  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1482  
 Signed Dave Trampe By driller performing actual drilling on site or contractor  
 Date 10/26/98

Date started 10/16, 1998  
 Date completed 10/17, 1998

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift		
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<i>Plugging of log #2503</i>		