

OFFICE USE ONLY  
 Log No. 73986  
 Permit No. \_\_\_\_\_  
 Basin. 212

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 32249

1. OWNER TAB ADDRESS AT WELL LOCATION in a Channel S of Owens  
 MAILING ADDRESS 3617 N 5th  
NLV NV

2. LOCATION 3W 1/4 S 1/4 Sec. 19 T 20 N 3R 62 E CLARK County  
 PERMIT NO. DW-10926 140.30-01-001 Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other BKT

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Fill</u>		<u>0</u>	<u>2</u>	<u>2</u>
<u>DIRTY Silty Clay</u>		<u>2</u>	<u>6</u>	<u>4</u>
<u>Silty Clay w/sand</u>		<u>6</u>	<u>16</u>	<u>10</u>
<u>Silty Sand w/Clay &amp; Gravel</u>		<u>16</u>	<u>26</u>	<u>10</u>
<u>Sandy Clay</u>		<u>26</u>	<u>30</u>	<u>4</u>

Driller  
ED DAVIDSON

8. WELL CONSTRUCTION  
 Depth Drilled 30 Feet Depth Cased 30 Feet

HOLE DIAMETER (BIT SIZE)  
 From 24 Inches To 30 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8</u>	<u>PVC</u>	<u>Sch 40</u>	<u>0</u>	<u>30</u>


Perforations:  
 Type perforation Slot  
 Size perforation 1052

From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From 10 feet to 30 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal: ~~Yes~~  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Placement Method:  Pumped  
 Poured

Gravel Packed:  Yes  No  
 From 10 feet to 30 feet



Date started 1-20-99, 19\_\_\_\_\_  
 Date completed 1-20-99, 19\_\_\_\_\_

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL  
 Static water level 11 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature 62 °F Quality Good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name GDC  
 Address 536 E Mainland  
ONTARIO CA

Nevada contractor's license number 31246  
 issued by the State Contractor's Board

Nevada driller's license number issued by the Division of Water Resources, the on-site driller. M1968

Signed [Signature]  
 By driller performing actual drilling on site or contractor

Date 1-20-99