

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO.18006

1. OWNER: Michaels/D. Kennedy ADDRESS AT WELL LOCATION: _____
 MAILING ADDRESS 1028 Bedford St., #2 4921 S. Allison Ct
L.A., CA Pahrump, NV
 2. LOCATION: SE 1/4 SE 1/4 Sec 36 T 21S N/S R 53E E Nye County
 PERMIT NO. 44-851-07 44-851-07 Parkos, Lot 13
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED: New Well Replace Recondition Deepen Abandon Other _____
 4. PROPOSED USE: Domestic Municipal/Industrial Irrigation Monitor Test Stock
 5. WELL TYPE: Cable Rotary RVC Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Surface		0	4	4
Broken Caliche/clay		4	16	12
Brown clay		16	28	12
Shale		28	35	7
Soft brown clay		35	92	57
Shale		92	98	6
Brown clay	X	98	192	94
Gypsum formation	X	192	200	8

8. WELL CONSTRUCTION
 Depth Drilled 200 Feet Depth Cased 200 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
 _____ Inches _____ Feet _____ Feet
12 Inches 0 Feet 200 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8"	17 3/4	.188	0	200

Perforations:
 Type perforation torch cut
 Size perforation 1" wide x 8" long
 From 1.60 feet to 200 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement Cement Grout Concrete Grout
 Depth of Seal 50'
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 50' feet to 200 feet

9. WATER LEVEL
 Static water level: 7.8 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Charles Nyberg Well Drilling Contractor
 Address 1060 W. Basin R. Contractor
Pahrump, NV 89048
 Nevada contractor's license number 7484 issued by the State Contractor's Board.
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 725
 Signed Charles Nyberg By driller performing actual drilling on site or contractor
 Date 2-28-99

Date started 2-16-99 19_____
 Date completed 2-19-99 19_____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input checked="" type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>20</u>	<u>-0-</u>	<u>15 min</u>

