

OFFICE USE ONLY
 Log No. 74137
 Permit No. 102
 Basin 29340

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 29340

1. OWNER W. Dennis D. Rose ADDRESS AT WELL LOCATION 7340 Citrus St Silver Springs, NV. 89429
 MAILING ADDRESS Box 7 S.S. NV 89425 N/S R 24 E. of 1st County Batt 2#
 2. LOCATION S 1/4 NW 1/4 Sec 13 T. 17 PERMIT NO. 117-234-11 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Mod

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Gravel</u>		<u>0</u>	<u>8</u>	
<u>Sand</u>		<u>8</u>	<u>46</u>	
<u>Clay</u>		<u>46</u>	<u>64</u>	
<u>Sand</u>		<u>64</u>	<u>98</u>	
<u>Indefinite gravel</u>		<u>98</u>	<u>196</u>	
<u>Blocky fractured</u>		<u>196</u>	<u>320</u>	

8. WELL CONSTRUCTION
 Depth Drilled 318 Feet Depth Cased 319 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
1 5/8 Inches 1 Feet 140 Feet
8 3/4 Inches 140 Feet 196 Feet
5 9/16 Inches 196 Feet 320 Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/16</u>	<u>13</u>	<u>1.88</u>	<u>1</u>	<u>196</u>
<u>5</u>	<u>10</u>	<u>1.88</u>	<u>196</u>	<u>320</u>

 Perforations:
 Type perforation Taper cut
 Size perforation 3/16 x 1 1/2 x 60 Den
 From 290 feet to 320 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 55 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 55 feet to 196 feet

Date started 11/11 1997
 Date completed 11/11 1997

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>1.5</u>		<u>4 hrs</u>

9. WATER LEVEL
 Static water level 157 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 60 °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name John D. Miller, Jr. Contractor
 Address PO Box 500 Contractor
S.S. NV 89425
 Nevada contractor's license number issued by the State Contractor's Board 0031841
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1870
 Signed W. Dennis D. Rose
 By driller performing actual drilling on site or contractor
 Date _____