

OFFICE USE ONLY
 Log No. 74222
 Permit No. _____
 Basin. 48

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 22117

1. OWNER Norm Peters ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS. 291-12 Pleasant Valley NW BLK J Lot 5
Pleasant Valley NV
 2. LOCATION NE 1/4 NW 1/4 Sec. 20 T. 33 R. 57 E. 21N0 County _____
 PERMIT NO. 23-008-05-5 Parcel No. _____ Subdivision Name _____
 Issued by Water Resources _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
TOP soil		0	2	2
Cobbles		2	18	16
Caliche		18	37	19
Granite		37	152	115
Gravel sand	X	152	153	1
Caliche		153	183	20
Gravel sand	X	183	198	15
Clay		198	205	7

8. WELL CONSTRUCTION
 Depth Drilled 205 Feet Depth Cased 205 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10 Inches 0 Feet 205 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>		<u>188</u>	<u>0</u>	<u>205</u>

 Perforations:
 Type perforation Factory
 Size perforation _____
 From 160 feet to 200 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 00 feet to 205 feet
 9. WATER LEVEL
 Static water level 103 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started OCT - 11, 1995
 Date completed OCT - 12, 1995

7. WELL TEST DATA

TEST METHOD: <input checked="" type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
<u>30</u>	<u>0</u>	<u>2</u>	

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name AAA Drilling Contractor
 Address 181-14 West Sullivan Contractor
21N0 NV
 Nevada contractor's license number 0020684
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 1438
 Division of Water Resources, the on-site driller
 Signed Shaw Bennett
 By driller performing actual drilling on site or contractor
 Date OCT 12 - 95